



- KEY NOTES: ○
1. THE ACCESS CONTROLLED DEVICES, SUCH AS, CARD READER, PANIC HARDWARE, CONCEALED VERTICAL ROD ETC, FOR INDICATED DOOR SHALL BE RECOVERED FROM PREVIOUS DOOR LOCATION. PROVIDE NEW SECTION OF CONDUITS AND ENTIRE LENGTH OF NEW CABLES FOR RELOCATED ACCESS CONTROL DOOR. RELOCATE EXISTING LOCK POWER SUPPLY TO TELECOM ROOM A-L2-436 (REFER TO SHEET SS10.001, DETAIL #3 FOR NEW LOCATION FOR LOCK POWER SUPPLY).

NO.	REVISION	DATE

PGAL
 201 N UNION ST.
 SUITE 500
 ALEXANDRIA,
 VIRGINIA 22314
 (T) 703 836 0588
 (F) 703 836 8027

Biggs Incorporated
 10621 GATEWAY BLVD.
 SUITE 106
 MANASSAS, VIRGINIA 20110
 TEL: (703) 365-0021
 FAX: (703) 361-9858

100%
 Design
 Submission

DATE	August 31, 2011
SCALE	1/8" = 1'=0"
DESIGNED	AKP
CHECKED	MTW
ACCEPTED	AKP
SUBMITTED	DLJ
APPROVED	DRH
	FDH

METROPOLITAN WASHINGTON AIRPORTS AUTHORITY

METROPOLITAN WASHINGTON AIRPORTS AUTHORITY
 OFFICE OF ENGINEERING DESIGN DEPARTMENT

GATE A23/25 - A31 STERILE CORRIDOR RENOVATION WASHINGTON DULLES INTERNATIONAL AIRPORT WASHINGTON, DC		PROJECT IDENTIFIER IT1111
SECURITY SYSTEMS CONCOURSE LEVEL FLOOR PLAN		SHEET NAME SS03.002
		VOLUME NUMBER 1 of 1
		SHEET NUMBER 27 of 35